

CEEP Energy Upgrade Specifications



Energy Upgrade

Attic Insulation

Wall Insulation

Floor Insulation

Duct Sealing & Insulating²

High Efficiency Windows

Ductless Heat Pump^{1**}

Ducted Heat Pump
Upgrade^{1**}

Ducted Heat Pump
Conversion^{1**}

Heat Pump Water Heater^{1**}

Exterior Entry Door²

Pre & Post Condition

R-0 to R-49 or more

R-0 to R-11 or fill capacity

R-0 to R-30 or more

≥ 30% of the ductwork is outside of the envelope; sealed and insulated to utility or Regional Technical Forum standards

Replaces single or double pane, wood or metal framed windows to ≤ U .30; vinyl windows to ≤ U .22

Replaces baseboard heating or electric forced air furnace, ≥ 8.1 HSPF2

Replaces 10+ year old ducted heat pump, ≥ 8.3 HSPF2

Replaces forced air furnace, ≥ 8.5 HSPF2

Replaces electric water heater; 50-80 gal.

ENERGY STAR™ rated; replaces standard 32" or 36" exterior entry door

ALL UPGRADES ARE FOR RETROFIT WORK ONLY. New construction, additions or unconditioned spaces do not qualify for incentives. All upgrades must be performed to RTF and/or utility company standards and be installed by a WA State licensed & bonded contractor, except for heat pump water heaters incentivized through CEEP.

Share this sheet with your contractor to ensure your upgrades meet the programs' energy upgrade specifications.

1 - Max one rebate per residence | 2 - Max two rebates per residence

**This equipment is subject to additional specifications if applying for WA State HEAR rebates.